



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP
Director

Dale J. Fletcher, CBO
Assistant Director

September 6, 2016

Matthew Doyle
Shasta Caverns
20359 Shasta Caverns Road
Lakehead, CA 96051

CITATION NO. 01_75_16C_010_4500248_25 FOR SHASTA CAVERNS WATER SYSTEM# 4500248, FAILURE TO COLLECT REPEAT SAMPLES AFTER A TOTAL COLIFORM POSTIVE ROUTINE BACTERIOLOGICAL SAMPLE

The Shasta Caverns Water System is classified as a transient/non-community public water system which is required to collect one routine bacteriological water sample each month. In the event that a routine bacteriological sample is positive for total coliform, the Water System is required to collect four repeat samples within 24 hours. On August 4, 2016, the Water System collected a routine bacteriological sample that resulted in a positive for total coliform, but did not collect four repeat samples within twenty-four hours.

Section 116650 of the California Health and Safety Code (CHSC) authorizes the issuance of a citation for failure to comply with requirements of the California Safe Drinking Water Act, or any regulation, standard, permit, or order issued thereunder. The Shasta County Environmental Health Division (SCEHD), under the delegated authority from the State Water Resources Control Board Division of Drinking Water, hereby issues a citation to the Shasta Caverns Water System for failure to comply with Section 64423(a), Title 22, of the California Code of Regulations (CCR).

The SCEHD has determined that the Water System violated Section 64424(a) (1), Title 22, of the CCR, in that the Water System did not collect four repeat samples following a positive total coliform routine sample in August of 2016.

The Water System is directed to take the following actions:

1. Comply with Section 64424(a) (1), Title 22, of the CCR in all future bacteriological monitoring.

☐ Suite 101
AIR QUALITY MANAGEMENT DISTRICT
530 225-5674
Fax 530 225-5237

☐ Suite 102
BUILDING DIVISION
530 225-5761
Fax 530 245-6468

☐ Suite 103
PLANNING DIVISION
530 225-5532
Fax 530 245-6468

☒ Suite 201
ENVIRONMENTAL HEALTH DIVISION
530 225-5787
Fax 530 225-5413

☐ Suite 200
ADMINISTRATION & COMMUNITY EDUCATION
530 225-5789
Fax 530 225-5807

Matthew Doyle
Page 2
September 6, 2016

2. Within 30 days of the issuance of this Citation, notify all persons served by the Water System of this violation as required by Section 64463.4 and Section 64465, Title 22, of the CCR. Notification shall be completed in accordance with the following:
 - a. Provide the notice contained in Attachment 'A' by posting in conspicuous locations throughout the area served by the water system. Changes and/or modification to Attachment 'A' shall not be made unless approved by the SCEHD.
3. Complete and return Attachment 'B' "Certification of Completion of Public Notification" form within 10 days of giving public notice. A copy of the notice used to provide public notification shall be attached to the form.

Failure to comply with the directives of this citation may result in further enforcement action with the possibility of administrative penalties.

Note that Section 116577 of the California Safe Drinking Water Act provides for the SCEHD to be reimbursed by the public water system for costs incurred for preparing and issuing a citation to that system. In accordance with Section 116577, Shasta Caverns Water System is hereby charged for the preparation and issuance of this letter. Our current costs are \$65.73 per hour. The estimated time to prepare this citation is one-half hour (\$32.87). Please submit your payment with the certification form requested in item 3 above within the next 45 days.

Please contact me at 530/225-5787, Monday through Friday, between 8:00 and 8:30 a.m. should you have any questions or concerns.

Sincerely,



Christy Gilbreath, REHS
Registered Environmental Health Specialist

CG/pw

Enclosures